

# Perspective on CCS – Cost, Energy & Scale

Energy Hub Workshop July 6, 2009 Emeryville


# Karl Gerdes Consulting Engineer Chevron Energy Technology Company

Email: karl.gerdes@chevron.com

# There are three main approaches to CO<sub>2</sub> Capture from combustion operations.

(And no silver bullets)

Chevron





#### A sense of scale

400 MW (net) NGCC -> 1.4 Mtpa of CO2

500 MW (net) SC PC -> 3.5 Mtpa of CO2

Chevron's Richmond Refinery -> ~4 Mtpa of CO2

# How big are the pipelines? 1

For 3.6 Mtpa about 12 inch ID

For 50 Mtpa about 28 inch ID

# How large is a Giga-tonne?

About 320 500-MW PC plants (~50% of current US name plate coal capacity)

Note 1: See "The Cost of CCS in the Perth Region," Allinson et al, SPE 101122-PP

© Chevron 2009

# **Post-Combustion CO<sub>2</sub> Capture**

Key CO<sub>2</sub> sources are boilers, heaters, and turbines

Flue gas is hot, low pressure, and dilute in CO<sub>2</sub> (4-10 vol.%)

Current technology is proven and is based on amine scrubbing using very large equipment

Large energy requirements for  $CO_2$  recovery Other flue gas components (e.g.,  $O_2$ ,  $NO_X$ ,  $SO_X$  degrade amines)

This picture shows the absorber (foreground) and the stripper for removing  $CO_2$  from the flue gases from an equivalent of a <u>40 MW</u> gas fired power plant.



ECONAMINE<sup>TM</sup> Unit at Bellingham, MA CO<sub>2</sub> Plant Courtesy of Val Francuz (Fluor) and Cliff Lowe (Chevron)



A 500 MW SCPC scrubber is 20m in diameter

© Chevron 2009

# **Issues/Barriers for Capture Technology (US DOE view circa 2004 ... and still true)**



#### **Post-Combustion Capture (the only industrially proven approach)**

- CO<sub>2</sub> in flue gas is dilute requiring large gas-handling systems.
- Other flue gas components (O<sub>2</sub>, SOx, NOx, particulate) adversely affect separation tech's.

#### **PreCombustion Decarbonization**

- Existing CO<sub>2</sub> removal tech's operate at low T, requiring syngas cooling/ reheat.
- Often cheaper to combust syngas before full shift, reducing fraction CO<sub>2</sub> captured.

#### **Oxy-Fired Combustion**

- Cryogenic air separation is costly.
- Pure oxy combustion T too high for existing materials & mediation by CO<sub>2</sub> recycle uses energy.

#### **Crosscutting Science**

- CO<sub>2</sub> capture tech's have poor selectivity and/or require significant heating/cooling.
- Decreased efficiency and resulting increased fuel use is going the wrong direction. AS MUCH AS 1/3 POWER PLANT OUTPUT.

**Bottom Line** 

CO<sub>2</sub> Capture is COSTLY!



# **Some rough costs**

### Post-combustion capture on H2 Plant<sup>1</sup>

- 8330 kmol/hr H2 releases ~1.2 mtpa CO2
- Capital cost of Amine Scrubber ~\$500 MM (4Q07)
- CO2 avoided cost \$71/tonne (85% capture)


### Post-C capture on small NGCC Plant<sup>2</sup>

- 660,000 mtpa CO2 captured (~200 MW)
- Capital cost of amine system ~\$350 MM
- CO2 avoided cost \$157/tonne (70% capture)

Note 1: "Designing a Climate Friendly H2 Plant,"Lindsay et al, GHGT9

Note 2: Internal study

© Chevron 2009





# **Summary**

CO<sub>2</sub> Capture is Costly.

- Perhaps 70% of total CCS cost chain.
- Economy of Scale is crucial.
- Promising technologies are emerging, but time is running out.
- There are no silver bullets economics are very site specific.

CO<sub>2</sub> Capture does not occur in a vacuum.

- Transportation infrastructure huge. How to pay?
- Secure storage sites.

The oil and gas industry has experience with all of these technologies, but none are demonstrated for widespread deployment.